


MODEL	SIZE	BY-PASS SIZE	L1	W1	H1	WEIGHT LBS
FMC-04	4"	2"	11'-6"	6'-0"	4'-6"	18,000
FMC-06	6"	3"	11'-6"	6'-0"	4'-9"	18,000
FMC-08	8"	4"	13'-6"	6'-0"	4'-9"	20,000
FMC-10	10"	4"	16'-0"	7'-0"	5'-0"	40,000

PLAN VIEW

NAMEPLATE INDICATING:  
MFG: ParkUSA  
888-611-PARK  
WWW.PARK-USA.COM  
MODEL: FMC-AL-SL  
DATE MANUFACTURED



ELEVATION

© Park 2017

## Specifications

**CONCRETE:** Class I/II concrete with design strength of 4500 PSI at 28 days. Unit is of monolithic construction at floor and first stage of wall with sectional riser to required depth.

**REINFORCEMENT:** Grade 60 reinforced. Steel rebar conforming to ASTM A615 on required centers or equal.

**ACCESS COVER:** 1/4" steel skid-resistant floor plate welded to 3" angle frame with (2) 3"x2-3/8" I-beam supports. Hatch to be furnished with 316 stainless steel bolts and hinges

**ACCESS HATCHWAY:** 1/4" Aluminum diamond plate cover with extruded aluminum frame. Hatch to be furnished with 316 stainless steel slam lock & hinges.

## Engineering Data

The meter assembly shall be factory assembled in vault & hydrostatically tested prior to delivery. Field excavation & preparation shall be complete prior to delivery. Pipe, valves and fittings of the assembly shall be approved by one or more of the following associations:



PROJECT:

CUSTOMER:

ENGINEER:

ORDER #:

PROJ #:

DATE:

888.611.PARK  
www.park-usa.com



FIRE & DOMESTIC COMBINATION WATER METER ASSEMBLY  
MODEL FMC - 4" THRU 10"

FMC-AL-SL

PM

DRN

ENG

DWG. NO.

REV.

DATE 08/2017

FMC-AL-SL

A