





CONCRETE: CLASS I/II CONCRETE WITH OF DESIGN STRENGTH OF

4500 PSI AT 28 DAYS. UNIT IS OF MONOLITHIC CONSTRUCTION INCLUDING WALLS AND FLOOR.

REINFORCEMENT: GRADE 60 REINFORCED. NO. 4 STEEL REBAR TO

CONFORM TO ASTM A615 ON REQUIRED CENTERS OR EQUAL. BAR BENDING AND PLACEMENT SHALL WITH

THE LATEST ACI STANDARDS.

ALL STEEL FABRICATION SHALL BE IN ACCORDANCE **GRATING:**

TO AWA D1.1. STEEL SHALL BE ASTM A36 CARBON STEEL, AND HOT-DIPPED GALVANIZED AFTER

FABRICATION IN ACCORDANCE TO ASTM A123

